

LISKEARD TOWN COUNCIL  
PUBLIC HALL, 3-5 WEST STREET, LISKEARD. PL14 6BW

## GENERAL RISK ASSESSMENT

Report created by Ellis Whittam Ltd  
Health & Safety Consultant: J Nicholson  
Visit Date: 12/05/2016



**elliswhittam**

Employment Law / HR / Health & Safety

# CONTENTS

INTRODUCTION	3
ABOUT RISK ASSESSMENT	4
OVERVIEW	5
SAFETY ACTION PLAN	6
RISK ASSESSMENTS	14
HEALTH AND SAFETY MANAGEMENT	38

## INTRODUCTION

This document, prepared on your behalf by Ellis Whittam Ltd, is your health and safety general risk assessment as required by the Management of Health and Safety at Work Regulations 1999, it identifies the significant health and safety issues that are relevant to your business.

The objective of this report is to inform you of what actions you must take to meet your legal obligations under the many and various pieces of health and safety legislation currently in force. In completing the actions recommended you will not only reduce the likelihood of legal action being taken against your company you will also reduce your liability to any claims brought by employees or others arising from an accident, incident or case of ill health.

Risk assessment is the key to successful health and safety management and is a legal duty found in many regulations, this report identifies within each of the subject general risk assessments **when you are required to carry out a more detailed and specific risk assessment.**

In compiling this report every effort has been made to cover the significant hazards likely to affect your business and is a result of the observations made by the consultant during his visit and discussions held with your staff. It is your responsibility to validate this report to ensure that all reasonably foreseeable hazards have been considered.

**REMEMBER ADVICE ON THIS REPORT OR ANY HEALTH AND SAFETY ISSUE  
IS AVAILABLE FROM THE ELLIS WHITTAM ADVICE LINE.**

**Tel: 0845 226 8393**

# ABOUT RISK ASSESSMENT

**Risk Assessment** involves identifying the hazards present either in the work place or arising out of any work activity, and evaluating the extent of the risks involved to employees and others, taking into account existing precautions and their effectiveness.

A **hazard** is something with a potential to cause harm and can include articles, substances, plant or machines, methods of work and the work environment.

**Risk** is the likelihood of harm from that hazard being realised. Risk increases with the number of people exposed to the hazard and also with the potential severity of the harm i.e.. The resultant injury or ill health effect. If there are no hazards there are no risks.

The regulations require the risk assessments to be '**suitable and sufficient**' in that they should identify all the significant hazards present within the business and its activities and should be proportionate to the risk. The assessment should cover all risks that are reasonably foreseeable.

The risk assessment must identify all those people who may be affected by the hazard, whether they are workers or others such as members of the public.

Your business may be controlling risks in various ways; determining the effectiveness of those controls is part of the risk assessment process.

Health and safety law does not demand absolute safety when considering what safety controls are required but the measures taken should go as far as is '**reasonably practicable**'; a balance between risk and costs, the greater the risk the greater the need to commit resources in terms of time and money to remove or control the risk.

It is a legal requirement that you bring the significant findings of this risk assessment to the attention of your employees.

## Explanation of Risk ratings used:

"Insignificant Risk" relates to an activity which presents no greater risk than that associated with life in general.

"Low Risk" relates to the occurrence of a minor injury or reversible minor health effect.

"Medium Risk" relates to the possibility of a serious injury or serious health effect.

"High Risk" relates to the highly probably occurrence of a fatal or major injury or irreversible health effect.

## OVERVIEW

Liskeard Town Council employes between 10 and 12 staff and is responsible for three large buildings within the town and three further public conveniences. In addition is also has responsibilities for outside areas including play parks

This report attempts to highlight certain hazards and issues with the current Health and Safety systems however does not provide an exhaustive list of risks. These will only become apparent when the Council reviews its risk assessments.

The main issues arising from the visit are clearly movement of peopkle and the potential risks of evacuation following a fire. The Public Hall regularly holds concerts, plays and event which can attract up to 300 people and there are concerns about warning and staffing levels

The top 5 health and safety issues requiring your attention over the next 12 months are:

1. Review the fire risk assessment for the Public Hall and the other premises using an approved fire assessor from the IFE.
2. Review evacuation procedures and training for the Public Hall and Museum
3. Undertake a Legionella assessment
4. Undertake an asbestos survey of each site
5. Obtain in house expertise in Health and Safety

You are however advised that every effort should be made to work through all the actions listed in your **SAFETY ACTION PLAN**.

# SAFETY ACTION PLAN

The Safety Action Plan that follows establishes priorities for those protective and preventative measures identified within your General Risk Assessments; it is simply a list of actions that you must now take control of by allocating the responsibility to an individual or group of individuals and by setting a time limit for action and entering this on the plan. By periodically reviewing this plan with the nominated employees you can effectively manage the progress that is being made in improving your company safety performance.

Enforcement Officers will expect to see evidence not only of completed risk assessments but also evidence of the action taken to address the control measures identified. By completing this plan you demonstrate progressive improvement and thereby a commitment to the management of health and safety within your business, a prerequisite in defending potential future legal action. The Courts accept that a business cannot complete all the actions required immediately but expect to see a managed and structured approach.

## Priorities explained

The actions required by your General Risk Assessment are prioritised as follows:

- 1 Immediate Action required**  
A condition or activity likely to cause an immediate risk of fatal or major injury (usually dealt with during the consultant's inspection).
- 2 Short term action required**  
Contravention of a legal requirement with a potential to cause a serious injury or ill health. It may result in a Prohibition Notice if not attended to.
- 3 Medium term action required**  
A legal contravention likely to result in injury or ill health which may result in an Improvement Notice if not attended to.
- 4 Longer term action required**  
Control inadequate or not in line with best practice/current guidance. Enforcement may follow if no action taken.
- 5 Review as part of Business Plan**  
No immediate risk to health or property. Action is desirable to meet current standards though costs not currently justified by risk.

## SAFETY ACTION PLAN

SUBJECT	ACTION REQUIRED	PRIORITY	ACTION DATE	COMPLETION DATE
Asbestos	It appears that all premises have been assessed for asbestos containing material however a recent incident has lead to question the competence of the assessor who has subsequently gone out of business. In view of the potential question over the competency we recommend further assessments are undertaken on all buildings by a competent assessor.	1	19/05/2016	
Fire Safety	It is recommended to review your fire assessment annually or more frequently if you make significant changes to the building. We consider the assessment for the Public Hall should be reviewed as there appears to be a good case for an automatic fire alarm throughout bearing in mind the potential for having 300 visitors. Early detection would be essential. At present it appears the under stage area is the only detection in the building. See report in 2014	1	19/05/2016	
Fire Safety	Liaise with tenants in the Guildhall to ensure they are aware of the fixed precautions provided e.g. smoke detection and sound of the alarm. They are responsible for their own evacuation	1	19/05/2016	
Fire Safety	Whilst the Council does have an evacuation plan it should be reviewed to ensure it is sufficient for each of the buildings i.e. the Public Hall's plan will be different from the Museum's. Also the Public Hall will have a different plan for an evening with entertainment (300 visitors) to the one were there is a smaller event such as a Council Meeting. All employees should be aware of their role. The Museum staff are unaware of their roles.	2	11/06/2016	
Fire Safety	All event organisers should provide the Council with a risk assessment of the activity such as The Lions' Pantomime. The assessment should consider access and egress in the event of an emergency as well as other risks	2	11/06/2016	
Fire Safety	Fit an automatic fire alarm. The Public Hall is a large and complex building which has large volumes of people within it. Early warning of a fire is essential for the safe evacuation and we would recommend an automatic alarm be discussed with your fire assessment advisors.	2	11/06/2016	

SUBJECT	ACTION REQUIRED	PRIORITY	ACTION DATE	COMPLETION DATE
Fire Safety	Several fire doors were not shutting properly and do not have either intumescent strips or smoke retardant foam around them. They do not form an effective seal and will not stop fire travelling	2	11/06/2016	
External Areas	The Council should arrange for an arboriculturalist to report on all the trees in its area and devise an on-going inspection regime to ensure they remain in good condition.	2	11/06/2016	
Asbestos	Prepare a written plan that sets out the location of the asbestos containing material and how the risk will be managed and the steps to be taken to put the plan into action. This must include informing tenants of the location and the need not to disturb it. The plan and the arrangements should be reviewed periodically.	3	10/08/2016	
Asbestos	Establish a procedure whereby any contractor liable to disturb asbestos containing materials is made aware of its location. An exchange of information between the Council and a contractor is essential to enable the contractor to put in place adequate precautions	3	10/08/2016	
Asbestos	Before any minor work is carried out on asbestos materials, an assessment of the potential exposure to asbestos must be carried out by a competent person and a written plan prepared of the work completed. Minor work could include decorating, hanging pictures etc.	3	10/08/2016	
COSHH	Carry out a COSHH Assessment for each hazardous substance in use or created.	3	10/08/2016	
COSHH	Develop a management system that ensures before any hazardous substance is taken into use a COSHH assessment is first completed and any actions determined put into place.	3	10/08/2016	
COSHH	Provide training for relevant employees that use hazardous substances.	3	10/08/2016	
COSHH	Record all training and information given to employees on the use of hazardous substances.	3	10/08/2016	



SUBJECT	ACTION REQUIRED	PRIORITY	ACTION DATE	COMPLETION DATE
COSHH	It was not clear what hazardous substances were used at the time of the meeting however cleaning products can have health effects which need to be considered when using and storing them. Certain items may react in a fire with others and should be stored safely. Refer to the data sheets for information.	3	10/08/2016	
Fire Safety	Carry out a fire drill at least once in every 12 month period. Record the data and results of the fire drill.	3	10/08/2016	
Fire Safety	Establish a procedure for the evacuation of disabled persons particularly in the event of a large show being put on.	3	10/08/2016	
Fire Safety	Ensure that a procedure is in place to call the emergency services in the event of a fire emergency. A member of staff will do this during working hours but to hirers know the procedure?	3	10/08/2016	
Fire Safety	The alarm system is tested in the Public Hall and the Museum however it was not clear whether the Guildhall alarm is tested. If it isn't, it should be. Record all tests.	3	10/08/2016	
Fire Safety	The fire door leading to from the Council chamber should have a vision panel to prevent it being opened into the path of another escapee from a different room	3	10/08/2016	
Fire Safety	The Long Room has no extinguishers and nor does the kitchen beside it	3	10/08/2016	
Fire Safety	Although the fire extinguishers are maintained there appears to be one or two missing from certain areas such as the Long Room. Review the level of extinguishers with your fire assessor.	3	10/08/2016	
Legionella Bacteria	Each building should be assessed for the presence or likelihood of Legionella	3	10/08/2016	

SUBJECT	ACTION REQUIRED	PRIORITY	ACTION DATE	COMPLETION DATE
Legionella Bacteria	Carry out a monthly check on the cold water entering the building and cold water at locations around the premises to verify that the temperature is below 20°C, the minimum growth temperature for legionella bacteria. Record all readings.	3	10/08/2016	
Legionella Bacteria	Carry out a monthly check on hot water outlets in rotation to verify that the hot water in circulation is above 50°C. Record all readings.	3	10/08/2016	
Lone Working	Undertake a risk assessment which covers work undertaken by lone workers. This should include the WC cleaner as well as the Foresters Hall cleaner and various other Council workers.	3	10/08/2016	
Lone Working	Ensure working when dark or at night is covered in the lone working risk assessment.	3	10/08/2016	
Lone Working	Risk assessment of young workers, women, new and expectant mothers and disabled should be included to ensure they are not put at any greater risk when working alone.	3	10/08/2016	
Lone Working	Ensure risk assessment for lone working covers where potential violence / criminal activity may place workers at higher risk.	3	10/08/2016	
Lone Working	Arrangements should be put in place to consult with staff on lone working either via a health and safety committee or directly.	3	10/08/2016	
Personal Protective Equipment (PPE)	Ensure risk assessments identify the need for PPE and who is required to wear it.	3	10/08/2016	
External Areas	The areas and equipment around the Town should be subject to inspection the frequency of which can be determined by risk assessment e.g. the memorial and Pipewell may be inspected monthly whereas Rapson Field and Thorn Park need a more frequent inspection.	3	10/08/2016	

SUBJECT	ACTION REQUIRED	PRIORITY	ACTION DATE	COMPLETION DATE
Work Equipment	Arrange for work equipment to undergo regular inspection and planned maintenance where appropriate.	3	10/08/2016	
Work Equipment	Complete work equipment risk assessments to identify the hazards, risks and control measures that are relevant to the operation and maintenance of each type of work equipment.	3	10/08/2016	
Work at Height	Before working at height a risk assessment must be completed.	3	10/08/2016	
Work at Height	Establish a safe system of work for all work at height. This includes the scaffold platform work, gutter cleaning etc.	3	10/08/2016	
Work at Height	Provide information and training for employees required to work at height, complete risk assessments or prepare systems of work.	3	10/08/2016	
Work at Height	Ensure those using the scaffold are trained properly including hirers.	3	10/08/2016	
Work at Height	All temporary working platforms including scaffolds and ladders etc. must be inspected before first use; after substantial additions, dismantling or other alteration	3	10/08/2016	
Health and Safety Policy	The Health and Safety Policy is being prepared by Ellis Whittam and will be sent to you in due course.	3	10/08/2016	
Employee Training	Provide all new staff with health and safety instruction as part of their induction training.	3	10/08/2016	
Accident / Incident Reporting	Make suitable arrangements to include near miss / incident reporting	3	10/08/2016	
Accident / Incident Reporting	Investigate the details of each serious accident/incident to identify the probable cause(s) and/or trends.	3	10/08/2016	

SUBJECT	ACTION REQUIRED	PRIORITY	ACTION DATE	COMPLETION DATE
Contractors	Review safety systems and procedures of contractors prior to engagement. Undertake assessment of health and safety standards adopted by the contractors.	3	10/08/2016	
Asbestos	Carry out labelling of all known asbestos containing materials.	4	08/11/2016	
Fire Safety	Review the level of lighting in the clock tower. The emergency lighting stops before the top. This may be adequate to light the entire area but it should be checked	4	08/11/2016	
Fire Safety	Train employees to use fire extinguishers so they can recognise the different types of fire extinguishers provided, know what sort of fire they are to be used on, and how to operate them quickly and efficiently.	4	08/11/2016	
Legionella Bacteria	Water systems should be disinfected before being taken into service and after shut downs of five or more days. Water systems should be disinfected periodically (normally annually) by chlorination or by temporarily raising water temperature.	4	08/11/2016	
Manual Handling	Identify activities likely to give rise to a manual handling injury and avoid these activities being carried out. Where tasks cannot be avoided then each task must be assessed to determine the measures required to reduce the risk of injury.	4	08/11/2016	
Manual Handling	Provide manual handling training to those employees identified by the manual handling assessment as being at risk. Record all training	4	08/11/2016	
Misc.	Fit red cord alarm pulls to the WCs	4	08/11/2016	
Temperature	Provide wall mounted thermometers, one to each area (not each work room)	4	08/11/2016	
Health and Safety Policy	The Health and Safety Policy must be brought to the attention of all staff and a record kept as evidence of compliance.	4	08/11/2016	

SUBJECT	ACTION REQUIRED	PRIORITY	ACTION DATE	COMPLETION DATE
Health and Safety Policy	The Health and Safety policy should be readily available for staff. Make the policy available by <placing on intranet, providing copy in staff room, signposting it's whereabouts on the notice board>	4	08/11/2016	
Health and Safety Policy	Clarify roles and responsibilities for health and safety, set these out in the H&S Policy and provide training to ensure competence of key persons. In particular it would be advisable to have a member of staff with a Health and Safety qualification or some training.	4	08/11/2016	
Monitoring and Measuring	Set suitable priorities for the safety action plan and monitor regularly	4	08/11/2016	
Monitoring and Measuring	Establish monitoring and performance criteria for health and safety. This will help work to a programme of continuous improvement.	4	08/11/2016	
Communication and consultation	Arrangements must be put into place for communicating with and consulting staff on Health and Safety matters.	4	08/11/2016	
Employee Training	Develop a programme of basic Health and Safety training for staff.	4	08/11/2016	
Risk Assessment	Ensure risk assessments are in place for specific activities that are not covered in the general risk assessment	4	08/11/2016	
Risk Assessment	Ensure competent persons are employed to carry out risk assessments.	4	08/11/2016	
Risk Assessment	Establish a programme of risk assessment review. This should be done at least annually and when any significant changes.	4	08/11/2016	
Risk Assessment	Ensure staff are given access to risk assessments and changes are notified.	4	08/11/2016	
Fire Safety	Consider replacing the stair nosings with colour contrasting ones. This is mainly in the Guildhall but other staircases could benefit from being more visible. Also the external granite stairs in the Public Hall	5		

# RISK ASSESSMENTS

- 1 Asbestos
- 2 COSHH
- 3 Electrical Safety
- 4 External Areas
- 5 Fire Safety
- 6 First Aid
- 7 Gas
- 8 Legionella bacteria
- 9 Lifting Equipment
- 10 Lone Working
- 11 Manual Handling
- 12 Misc
- 13 Personal Protective Equipment
- 14 Work at Height
- 15 Work Equipment
- 16 Workplace H&S
- 17 H&S Management

**RISK ASSESSMENT: Asbestos**

<b>HAZARDS:</b> <i>Inhalation of asbestos fibres</i>			<b>RISK:</b> High	
<b>CURRENT CONTROLS</b>	<b>YES</b>	<b>NO</b>	<b>ACTION REQUIRED</b>	<b>PRIORITY</b>
The premises have been surveyed to identify the presence of asbestos by a competent person.		<b>No</b>	It appears that all premises have been assessed for asbestos containing material however a recent incident has lead to question the competence of the assessor who has subsequently gone out of business. In view of the potential question over the competency we recommend further assessments are undertaken on all buildings by a competent assessor.	<b>1</b>
A plan or register showing the location of all asbestos containing materials and presumed asbestos containing materials will be made available.		<b>No</b>	Prepare a written plan that sets out the location of the asbestos containing material and how the risk will be managed and the steps to be taken to put the plan into action. This must include informing tenants of the location and the need not to disturb it. The plan and the arrangements should be reviewed periodically.	<b>3</b>
A procedure is in place to ensure that anyone liable to disturb asbestos containing materials is made aware of its location.		<b>No</b>	Establish a procedure whereby any contractor liable to disturb asbestos containing materials is made aware of its location. An exchange of information between the Council and a contractor is essential to enable the contractor to put in place adequate precautions	<b>3</b>
Where minor work on asbestos material is carried out a risk assessment is completed.		<b>No</b>	Before any minor work is carried out on asbestos materials, an assessment of the potential exposure to asbestos must be carried out by a competent person and a written plan prepared of the work completed. Minor work could include decorating, hanging pictures etc.	<b>3</b>
Asbestos containing material is labelled.		<b>No</b>	Carry out labelling of all known asbestos containing materials.	<b>4</b>

**Person(s) Exposed:**

<b>Person(s)1</b>	All Employees
<b>Person(s)2</b>	Contractors
<b>Person(s)3</b>	Visitors

**RISK ASSESSMENT: COSHH**

<b>HAZARDS:</b> <i>Hazardous substances including: Cleaning products, maintenance items such as oils and lubricants etc.</i>	<b>RISK:</b> Low
---	---------------------

CURRENT CONTROLS	YES	NO	ACTION REQUIRED	PRIORITY
A list of the hazardous substances used on the premises has been created.	Yes		Maintain and monitor existing controls.	
Health and safety data sheets have been obtained from the suppliers for all substances hazardous to health used or stored.	Yes		Maintain and monitor existing controls.	
An assessment of the health risk to each employee for each hazardous substance has been carried out.		No	Carry out a COSHH Assessment for each hazardous substance in use or created.	3
Procedures are in place to ensure that work liable to expose employees to substances hazardous to health is not carried out unless a suitable and sufficient COSHH assessment has been made.		No	Develop a management system that ensures before any hazardous substance is taken into use a COSHH assessment is first completed and any actions determined put into place.	3
Training is provided in the use of hazardous substances.		No	Provide training for relevant employees that use hazardous substances.	3
Training records are kept for each employee.		No	Record all training and information given to employees on the use of hazardous substances.	3
Substances hazardous to health are stored safely.		No	It was not clear what hazardous substances were used at the time of the meeting however cleaning products can have health effects which need to be considered when using and storing them. Certain items may react in a fire with others and should be stored safely. Refer to the data sheets for information.	3



CURRENT CONTROLS	YES	NO	ACTION REQUIRED	PRIORITY
Protective clothing and equipment is provided to the employees exposed to hazardous substances.	Yes		Maintain and monitor existing controls.	

**Person(s) Exposed:**

Person(s)1	Cleaning Staff
Person(s)2	Maintenance Staff

**RISK ASSESSMENT: Electrical Safety**

<b>HAZARDS:</b> <i>Electric shock</i> <i>Fire</i>	<b>RISK:</b> Low Low
---	----------------------------

CURRENT CONTROLS	YES	NO	ACTION REQUIRED	PRIORITY
The fixed electrical wiring has been tested and a current certificate of inspection is kept on file.	Yes		Maintain and monitor existing controls.	
Inspection and testing of all portable electrical appliances is regularly undertaken by a competent person.	Yes		Maintain and monitor existing controls.	
There is an inventory of all portable electrical appliances in use.	Yes		Maintain and monitor existing controls.	
All recommendations from the fixed electrical wiring certificate have been completed	Yes		Maintain and monitor existing controls.	
Adequate electrical sockets are available throughout the premises to minimise the need to have multi-point adapter sockets or trailing cables.	Yes		Maintain and monitor existing controls.	
Employees who carry out electrical work are competent to do so.	Yes		Maintain and monitor existing controls.	
Electrical switchgear areas are free from storage of combustible products.	Yes		Maintain and monitor existing controls.	

**Person(s) Exposed:**

<b>Person(s)1</b>	All Employees
<b>Person(s)2</b>	Contractors
<b>Person(s)3</b>	Visitors

**RISK ASSESSMENT: External Areas**

<b>HAZARDS:</b> <i>Failure of equipment</i> <i>Vandalism</i> <i>Falling trees and branches</i>	<b>RISK:</b> Medium Medium
---	----------------------------------

CURRENT CONTROLS	YES	NO	ACTION REQUIRED	PRIORITY
Areas under the custody and control of the Council have been identified	<b>Yes</b>		Maintain and monitor existing controls.	
Play areas are subject to an annual inspection by a trained competent inspector	<b>Yes</b>		Maintain and monitor existing controls.	
Play equipment is also subject to an documented inspection at least weekly	<b>Yes</b>		Maintain and monitor existing controls.	
External areas, grounds, walkways are subject to regular inspection		<b>No</b>	The areas and equipment around the Town should be subject to inspection the frequency of which can be determined by risk assessment e.g. the memorial and Pipewell may be inspected monthly whereas Rapson Field and Thorn Park need a more frequent inspection.	<b>3</b>

**Person(s) Exposed:**

<b>Person(s)1</b>	Visitors
-------------------	----------

**RISK ASSESSMENT: Fire Safety**

<b>HAZARDS:</b>	<b>RISK:</b>
<b>Sources of Ignition:</b> electricity including portable appliances gas fired equipment smoking	Medium Low Low
<b>Combustible material:</b> paper, packaging, fixtures and furnishings	Medium

CURRENT CONTROLS	YES	NO	ACTION REQUIRED	PRIORITY
A specific fire risk assessment has been carried out on each of the premises.	Yes		Maintain and monitor existing controls.	
The fire risk assessment is reviewed periodically.		No	It is recommended to review your fire assessment annually or more frequently if you make significant changes to the building. We consider the assessment for the Public Hall should be reviewed as there appears to be a good case for an automatic fire alarm throughout bearing in mind the potential for having 300 visitors. Early detection would be essential. At present it appears the under stage area is the only detection in the building. See report in 2014	1
The recommendations from your fire risk assessment have been implemented.	Yes		Maintain and monitor existing controls.	
A fire evacuation plan has been prepared and all employees are familiar with their role in its implementation.	Yes		Maintain and monitor existing controls.	
All employees have been given instructions and training in the fire evacuation plan.		No	Whilst the Council does have an evacuation plan it should be reviewed to ensure it is sufficient for each of the buildings i.e. the Public Hall's plan will be different from the Museum's. Also the Public Hall will have a different plan for an evening with entertainment (300 visitors) to the one were there is a smaller event such as a Council Meeting. All employees should be aware of their role. The Museum staff are unaware of their roles.	2

<b>CURRENT CONTROLS</b>	<b>YES</b>	<b>NO</b>	<b>ACTION REQUIRED</b>	<b>PRIORITY</b>
Arrangements have been made with other occupants of the building to ensure the safety of employees and others in the event of fire.		<b>No</b>	Liaise with tenants in the Guildhall to ensure they are aware of the fixed precautions provided e.g. smoke detection and sound of the alarm. They are responsible for their own evacuation	<b>1</b>
Signs and/or notices specifying the action to be taken in the event of a fire are clearly displayed around the premises.	<b>Yes</b>		Maintain and monitor existing controls.	
Periodic fire drills are carried out.		<b>No</b>	Carry out a fire drill at least once in every 12 month period. Record the data and results of the fire drill.	<b>3</b>
Checks are made with larger event organisers that adequate safety measure are in place		<b>No</b>	All event organisers should provide the Council with a risk assessment of the activity such as The Lions' Pantomime. The assessment should consider access and egress in the event of an emergency as well as other risks	<b>2</b>
Arrangements have been made for the evacuation of disabled persons.		<b>No</b>	Establish a procedure for the evacuation of disabled persons particularly in the event of a large show being put on.	<b>3</b>
Suitable procedures are in place for the calling of emergency services.		<b>No</b>	Ensure that a procedure is in place to call the emergency services in the event of a fire emergency. A member of staff will do this during working hours but to hirers know the procedure?	<b>3</b>
Arrangements are in place to liaise with the emergency services in the event of a fire situation.	<b>Yes</b>		Maintain and monitor existing controls.	
The premises are fitted with a fire alarm.		<b>No</b>	Fit an automatic fire alarm. The Public Hall is a large and complex building which has large volumes of people within it. Early warning of a fire is essential for the safe evacuation and we would recommend an automatic alarm be discussed with your fire assessment advisors.	<b>2</b>
The fire alarm is audible in all occupied parts of the building.	<b>Yes</b>		Maintain and monitor existing controls.	
The fire alarm is tested at weekly intervals in all premises, from a different call point, by in-house personnel for compliance with the current standards and suitable records are maintained.		<b>No</b>	The alarm system is tested in the Public Hall and the Museum however it was not clear whether the Guildhall alarm is tested. If it isn't, it should be. Record all tests.	<b>3</b>

<b>CURRENT CONTROLS</b>	<b>YES</b>	<b>NO</b>	<b>ACTION REQUIRED</b>	<b>PRIORITY</b>
The fire alarm system is tested and maintained by a competent person/company.	<b>Yes</b>		Maintain and monitor existing controls.	
A designated fire assembly point has been provided.	<b>Yes</b>		Maintain and monitor existing controls.	
Self closing fire resistant doors are fitted to protect fire escape routes.	<b>Yes</b>		Maintain and monitor existing controls.	
All self closing fire resistant doors are functioning correctly.		<b>No</b>	Several fire doors were not shutting properly and do not have either intumescent strips or smoke retardant foam around them. They do not form an effective seal and will not stop fire travelling	<b>2</b>
Staircases have colour contrasting stair nosings.		<b>No</b>	Consider replacing the stair nosings with colour contrasting ones. This is mainly in the Guildhall but other staircases could benefit from being more visible. Also the external granite stairs in the Public Hall	<b>5</b>
A choice of escape route is provided and these can be reached within 1 minute.	<b>Yes</b>		Maintain and monitor existing controls.	
Means of escape routes within the building and final exits have adequate emergency lighting.	<b>Yes</b>		Maintain and monitor existing controls.	
The emergency lighting system is tested regularly.	<b>Yes</b>		Maintain and monitor existing controls.	
Fire doors leading to staircases have a vision panel		<b>No</b>	The fire door leading to from the Council chamber should have a vision panel to prevent it being opened into the path of another escapee from a different room	<b>3</b>
Fire evacuation is adequate in all premises		<b>No</b>	Review the level of lighting in the clock tower. The emergency lighting stops before the top. This may be adequate to light the entire area but it should be checked	<b>4</b>
An adequate amount of fire extinguishers have been provided.		<b>No</b>	The Long Room has no extinguishers and nor does the kitchen beside it	<b>3</b>

<b>CURRENT CONTROLS</b>	<b>YES</b>	<b>NO</b>	<b>ACTION REQUIRED</b>	<b>PRIORITY</b>
All fire extinguishers are annually inspected and serviced by a competent person.		<b>No</b>	Although the fire extinguishers are maintained there appears to be one or two missing from certain areas such as the Long Room. Review the level of extinguishers with your fire assessor.	<b>3</b>
Employees have been trained on the operational use of portable fire extinguishers.		<b>No</b>	Train employees to use fire extinguishers so they can recognise the different types of fire extinguishers provided, know what sort of fire they are to be used on, and how to operate them quickly and efficiently.	<b>4</b>
A fire blanket is provided in the kitchens.	<b>Yes</b>		Maintain and monitor existing controls.	
Fire safety signs conform to the requirements of the Health and Safety (Safety Signs and Signals) Regulations.	<b>Yes</b>		Maintain and monitor existing controls.	
All lifts are signed as to the prohibition of their use in event of a fire/emergency.	<b>Yes</b>		Maintain and monitor existing controls.	

**Person(s) Exposed:**

<b>Person(s)1</b>	All Employees
<b>Person(s)2</b>	Visitors

**RISK ASSESSMENT: First Aid**

<b>HAZARDS:</b> <i>Delayed administration of first aid may lead to the consequences of injuries/ill health being exacerbated.</i>	<b>RISK:</b> Low
--	---------------------

CURRENT CONTROLS	YES	NO	ACTION REQUIRED	PRIORITY
An adequate number of Appointed Persons for first aid are provided.	<b>Yes</b>		Maintain and monitor existing controls.	
First aid boxes are provided at key locations accessible to all employees.	<b>Yes</b>		Maintain and monitor existing controls.	
Persons have been nominated to take charge of the first aid kits and ensure they are kept fully stocked.	<b>Yes</b>		Maintain and monitor existing controls.	

**Person(s) Exposed:**

<b>Person(s)1</b>	All Employees
-------------------	---------------



**RISK ASSESSMENT: Gas**

<b>HAZARDS:</b> <i>Fire</i> <i>Explosion</i>	<b>RISK:</b> Low Low
--	----------------------------

CURRENT CONTROLS	YES	NO	ACTION REQUIRED	PRIORITY
The premises' gas appliances and installation/supply pipes are subject to regular annual inspection by a competent person.	<b>Yes</b>		Maintain and monitor existing controls.	
Records are maintained of the inspection and servicing of gas appliances and installation.	<b>Yes</b>		Maintain and monitor existing controls.	
Gas pipework is protected from damage by vehicles by the provision of robust barriers or is safe by position.	<b>Yes</b>		Maintain and monitor existing controls.	

**Person(s) Exposed:**

<b>Person(s)1</b>	All Employees
-------------------	---------------

**RISK ASSESSMENT: Legionella Bacteria**

<b>HAZARDS:</b>	<b>RISK:</b>
<i>Inhalation of legionella bacteria</i>	Medium
<i>The multiplication of legionella in domestic water systems</i>	Medium
<i>The release of water spray from taps, showers, spas or whirlpools, pools and hydrotherapy pools, humidifiers, fountains, evaporative condensers, cooling towers.</i>	Medium

CURRENT CONTROLS	YES	NO	ACTION REQUIRED	PRIORITY
The premises have been assessed to identify potential sources of legionella growth and dissemination.		No	Each building should be assessed for the presence or likelihood of Legionella	3
Cold water entering the building and stored in tanks is monitored to ensure that it is not at a temperature to prevent the growth of legionella bacteria.		No	Carry out a monthly check on the cold water entering the building and cold water at locations around the premises to verify that the temperature is below 20°C, the minimum growth temperature for legionella bacteria. Record all readings.	3
Hot water temperature is monitored to ensure that it is at a temperature to prevent the growth of legionella bacteria.		No	Carry out a monthly check on hot water outlets in rotation to verify that the hot water in circulation is above 50°C. Record all readings.	3
The domestic water system is subject to routine maintenance.		No	Water systems should be disinfected before being taken into service and after shut downs of five or more days. Water systems should be disinfected periodically (normally annually) by chlorination or by temporarily raising water temperature.	4

**Person(s) Exposed:**

Person(s)1	Visitors
------------	----------

**RISK ASSESSMENT: Lifting Equipment**

<b>HAZARDS:</b> <i>Passenger Lift in the Museum, Dumb Waiter in Public Hall and Stair Lifts in Public Hall</i>	<b>RISK:</b>  Low
---	-------------------------

CURRENT CONTROLS	YES	NO	ACTION REQUIRED	PRIORITY
All lifting equipment (including accessories) are sufficiently strong, stable and suitable for use.	Yes		Maintain and monitor existing controls.	
Emergency arrangements have been established.	Yes		Maintain and monitor existing controls.	
Lifting equipment is serviced to ensure it is maintained in a safe condition.	Yes		Maintain and monitor existing controls.	
Lifting equipment has an examination scheme drawn up by competent person.	Yes		Maintain and monitor existing controls.	
Equipment used is subject to thorough examination at least annually or every 6 months (if lifting people) or more frequent is specified by examination scheme.	Yes		Maintain and monitor existing controls.	
Thorough examination reports are submitted to the company detailing results of inspection and any actions required.	Yes		Maintain and monitor existing controls.	

**Person(s) Exposed:**

<b>Person(s)1</b>	All Employees
<b>Person(s)2</b>	Visitors

**RISK ASSESSMENT: Lone Working**

<b>HAZARDS:</b>	<b>RISK:</b>
<i>Lone Working in: Public toilets cleaning, office after hours etc.</i>	Medium
<i>Delayed access to first aid / emergency services</i>	Medium
<i>Unsafe use of work equipment, manual handling</i>	Medium
<i>Lack of supervision.</i>	Medium
<i>Violence / aggression</i>	Medium

<b>CURRENT CONTROLS</b>	<b>YES</b>	<b>NO</b>	<b>ACTION REQUIRED</b>	<b>PRIORITY</b>
An assessment of lone working activities has been undertaken		<b>No</b>	Undertake a risk assessment which covers work undertaken by lone workers. This should include the WC cleaner as well as the Foresters Hall cleaner and various other Council workers.	<b>3</b>
Where lone working is required when dark or at night this has been covered in the risk assessment		<b>No</b>	Ensure working when dark or at night is covered in the lone working risk assessment.	<b>3</b>
Where young workers, women, new or expectant mothers or disabled workers are at greater risk, this has been covered in the risk assessment.			Risk assessment of young workers, women, new and expectant mothers and disabled should be included to ensure they are not put at any greater risk when working alone.	<b>3</b>
Where potential violence / criminal activity may be involved, this has been covered in the risk assessment.		<b>No</b>	Ensure risk assessment for lone working covers where potential violence / criminal activity may place workers at higher risk.	<b>3</b>
Staff have been consulted on lone working either directly or via representatives.		<b>No</b>	Arrangements should be put in place to consult with staff on lone working either via a health and safety committee or directly.	<b>3</b>

**Person(s) Exposed:**

<b>Person(s)1</b>	All Employees
<b>Person(s)2</b>	Cleaning Staff

**RISK ASSESSMENT: Manual Handling**

<b>HAZARDS:</b> <i>Musculoskeletal injuries arising from: Moving equipment, chairs and tables etc.</i>	<b>RISK:</b> Medium
---	------------------------

CURRENT CONTROLS	YES	NO	ACTION REQUIRED	PRIORITY
Wherever practical the manual handling of loads likely to result in a risk of injury is avoided.	<b>Yes</b>		Maintain and monitor existing controls.	
Manual handling assessments have been completed.		<b>No</b>	Identify activities likely to give rise to a manual handling injury and avoid these activities being carried out. Where tasks cannot be avoided then each task must be assessed to determine the measures required to reduce the risk of injury.	<b>4</b>
Manual handling training has been provided for employees.		<b>No</b>	Provide manual handling training to those employees identified by the manual handling assessment as being at risk. Record all training	<b>4</b>

**Person(s) Exposed:**

<b>Person(s)1</b>	All Employees
-------------------	---------------

**RISK ASSESSMENT: Misc. All premises**

<b>HAZARDS:</b> <i>Miscellaneous hazards throughout Council activities</i>	<b>RISK:</b> Medium
---	------------------------

<b>CURRENT CONTROLS</b>	<b>YES</b>	<b>NO</b>	<b>ACTION REQUIRED</b>	<b>PRIORITY</b>
Disable WCs have red cord alarms		<b>No</b>	Fit red cord alarm pulls to the WCs	<b>4</b>
The lighting is suitable and sufficient	<b>Yes</b>		Maintain and monitor existing controls.	

**Person(s) Exposed:**

<b>Person(s)1</b>	All Employees
-------------------	---------------

**RISK ASSESSMENT: Personal Protective Equipment (PPE)**

<b>HAZARDS:</b> <i>Failure to provide the correct PPE for the risks involved.</i> <i>Employees fail to wear the designated PPE.</i> <i>Worn, damaged or ineffective PPE.</i>	<b>RISK:</b> Medium Medium Medium
---	--

CURRENT CONTROLS	YES	NO	ACTION REQUIRED	PRIORITY
Risk assessments have been carried out to determine the need for PPE.		<b>No</b>	Ensure risk assessments identify the need for PPE and who is required to wear it.	<b>3</b>
Employees are issued with PPE appropriate to the hazards to which they may be exposed.	<b>Yes</b>		Maintain and monitor existing controls.	
Employees receive instruction and training in the wearing of PPE.	<b>Yes</b>		Maintain and monitor existing controls.	

**Person(s) Exposed:**

<b>Person(s)1</b>	All Employees
-------------------	---------------

**RISK ASSESSMENT: Work at Height**

<b>HAZARDS:</b>	<b>RISK:</b>
<i>Undertaking maintenance work on overhead systems such as conveyors</i>	Medium
<i>Installing lighting systems</i>	Medium
<i>Work on ladders, e.g. cleaning of windows and other structures</i>	Medium
<i>Work on staging or trestles, e.g. erecting bill posters and painting and decorating</i>	Medium
<i>Most construction work</i>	Medium
<i>Erection of scaffolding and other steelwork</i>	Medium
<i>Any activity undertaken from a scaffold or from a mobile-elevated work platform</i>	Medium
<i>Work on permanent structures such as gantries, pylons and street lighting</i>	Medium

<b>CURRENT CONTROLS</b>	<b>YES</b>	<b>NO</b>	<b>ACTION REQUIRED</b>	<b>PRIORITY</b>
If work at height is carried out then a risk assessment is completed first.		<b>No</b>	Before working at height a risk assessment must be completed.	<b>3</b>
All necessary equipment is provided to ensure safe access to and egress from a place of work.	<b>Yes</b>		Maintain and monitor existing controls.	
All work at height is properly planned.	<b>Yes</b>		Maintain and monitor existing controls.	
Safe systems for work at height have been established.		<b>No</b>	Establish a safe system of work for all work at height. This includes the scaffold platform work, gutter cleaning etc.	<b>3</b>
Those who work, plan or supervise work at height are competent and properly trained.		<b>No</b>	Provide information and training for employees required to work at height, complete risk assessments or prepare systems of work.	<b>3</b>
Arrangements are in place to check the competency of those using the scaffold.		<b>No</b>	Ensure those using the scaffold are trained properly including hirers.	<b>3</b>
All ladders used are metal and conform to British Standard BS EN 131-1	<b>Yes</b>		Maintain and monitor existing controls.	



CURRENT CONTROLS	YES	NO	ACTION REQUIRED	PRIORITY
Ladders are only to be used as a means of access and egress where other work equipment is not justified because of the low risk and short duration of the job or unalterable features of the worksite.	Yes		Maintain and monitor existing controls.	
Temporary working platforms are subject to inspection.		No	All temporary working platforms including scaffolds and ladders etc. must be inspected before first use; after substantial additions, dismantling or other alteration	3

**Person(s) Exposed:**

Person(s)1	Maintenance Staff
------------	-------------------

**RISK ASSESSMENT: Work Equipment**

<b>HAZARDS:</b> <i>Misuse of equipment</i> <i>Insufficient guarding</i> <i>Use by un-trained personnel</i>			<b>RISK:</b> Medium Medium Medium	
<b>CURRENT CONTROLS</b>	<b>YES</b>	<b>NO</b>	<b>ACTION REQUIRED</b>	<b>PRIORITY</b>
Work equipment is subject to a planned maintenance system / inspection programme.		<b>No</b>	Arrange for work equipment to undergo regular inspection and planned maintenance where appropriate.	<b>3</b>
Work equipment risk assessments have been completed.		<b>No</b>	Complete work equipment risk assessments to identify the hazards, risks and control measures that are relevant to the operation and maintenance of each type of work equipment.	<b>3</b>

**Person(s) Exposed:**

<b>Person(s)1</b>	All Employees
<b>Person(s)2</b>	Maintenance Staff

**Workplace Health & Safety**

<b>CURRENT CONTROLS</b>	<b>YES</b>	<b>NO</b>	<b>ACTION REQUIRED</b>	<b>PRIORITY</b>
<b>Ventilation</b>			<b>Managing Ventilation</b>	
An adequate supply of air is provided either through mechanical ventilation or openings /windows, such that stale air / fumes are removed.	<b>Yes</b>		Maintain and monitor existing controls.	
Air inlets are position away from any flues and exhaust ventilation systems.	<b>Yes</b>		Maintain and monitor existing controls.	
Mechanical and air conditioning systems are regularly maintained and cleaned to ensure they are kept clean and free from anything that could contaminate the air.	<b>Yes</b>		Maintain and monitor existing controls.	
<b>Temperature</b>			<b>Managing Temperature</b>	
Wall mounted thermometers are available to monitor the temperatures		<b>No</b>	Provide wall mounted thermometers, one to each area (not each work room)	<b>4</b>
Workroom temperature is suitably maintained at a comfortable level and at least 16°C for office areas and 13°C for when work involves substantial physical activity.	<b>Yes</b>		Maintain and monitor existing controls.	
All reasonable effort has been made to maintain temperature at a comfortable level when working with hot / cold processes.	<b>Yes</b>		Maintain and monitor existing controls.	
Rest areas, toilets, showers, and changing rooms are maintained at a comfortable level.	<b>Yes</b>		Maintain and monitor existing controls.	
<b>Lighting</b>			<b>Managing Lighting</b>	
The workplace including stairs and facilities are sufficiently lit by a combination of natural light and artificial lighting.	<b>Yes</b>		Maintain and monitor existing controls.	

<b>CURRENT CONTROLS</b>	<b>YES</b>	<b>NO</b>	<b>ACTION REQUIRED</b>	<b>PRIORITY</b>
Lighting on traffic routes is adequate so people / vehicles can move around safely.	Yes		Maintain and monitor existing controls.	
Adequate lighting is provided to all of the external areas.	Yes		Maintain and monitor existing controls.	
<b>Cleanliness and waste materials</b>			<b>Managing cleanliness and waste materials</b>	
The furniture, walls and floor are kept clean and in good decorative order	Yes		Maintain and monitor existing controls.	
General housekeeping is adequate and the accommodation is tidy and free from any waste build up and any slipping or tripping hazards.	Yes		Maintain and monitor existing controls.	
Adequate and suitable waste receptacles are provided throughout the workplace.	Yes		Maintain and monitor existing controls.	
<b>Room dimensions and space</b>			<b>Managing room dimensions and space</b>	
Workrooms have enough free space to allow people to get to and from workstations and to move with ease.	Yes		Maintain and monitor existing controls.	
<b>Workstations and seating</b>			<b>Managing workstations and seating</b>	
Suitable seating and workstations are provided for workers which enable them to undertake their roles safely and comfortably.	Yes		Maintain and monitor existing controls.	
Seating provided gives adequate support for the lower back and footrests are provided for those that need them.	Yes		Maintain and monitor existing controls.	
<b>Floors and traffic routes</b>			<b>Managing floors and traffic routes</b>	
The floors are free from slipping and tripping hazards.	Yes		Maintain and monitor existing controls.	
The floors/floor coverings are in good condition.	Yes		Maintain and monitor existing controls.	
Access steps into the premises are in good condition.	Yes		Maintain and monitor existing controls.	

CURRENT CONTROLS	YES	NO	ACTION REQUIRED	PRIORITY
<b>Falls or falling objects</b>			<b>Managing falls and falling objects</b>	
Stored materials and objects are stable.	Yes		Maintain and monitor existing controls.	
Shelving is strong and secure and suitable for the materials stored on it.	Yes		Maintain and monitor existing controls.	
<b>Welfare Arrangements</b>			<b>Managing Welfare Arrangements</b>	
Suitable and sufficient sanitary conveniences are provided and readily accessible.	Yes		Maintain and monitor existing controls.	
Sanitary conveniences have warm/hot water, soap and means of drying.	Yes		Maintain and monitor existing controls.	
Sanitary conveniences are suitably ventilated, lit and kept clean.	Yes		Maintain and monitor existing controls.	
An adequate supply of water is readily available and cups provided.	Yes		Maintain and monitor existing controls.	
Suitable and sufficient rest areas are provided with seating and with clean surface on which to place food.	Yes		Maintain and monitor existing controls.	
The rest area includes the facility to prepare or obtain a hot drink.	Yes		Maintain and monitor existing controls.	
A means of heating food is provided where hot food cannot be obtained nearby.	Yes		Maintain and monitor existing controls.	

**Person(s) Exposed:**

<b>Person(s)1</b>	All Employees
-------------------	---------------

**Health & Safety Management**

<b>CURRENT CONTROLS</b>	<b>YES</b>	<b>NO</b>	<b>ACTION REQUIRED</b>	<b>PRIORITY</b>
<b>Health and Safety Policy</b>			<b>Managing Health and Safety Policy</b>	
The Health and Safety Policy is current and up to date.		<b>No</b>	The Health and Safety Policy is being prepared by Ellis Whittam and will be sent to you in due course.	<b>3</b>
The Health and Safety Policy has been brought to the attention of staff and a record of this has been made to demonstrate compliance.		<b>No</b>	The Health and Safety Policy must be brought to the attention of all staff and a record kept as evidence of compliance.	<b>4</b>
The Health and Safety Policy is made available to all staff		<b>No</b>	The Health and Safety policy should be readily available for staff. Make the policy available by <placing on intranet, providing copy in staff room, signposting it's whereabouts on the notice board>	<b>4</b>
<b>Organisation</b>			<b>Managing Organisation</b>	
The Company has an effective organisation in place for the management of health and safety .		<b>No</b>	Clarify roles and responsibilities for health and safety, set these out in the H&S Policy and provide training to ensure competence of key persons. In particular it would be advisable to have a member of staff with a Health and Safety qualification or some training.	<b>4</b>
The Town Clerk has accepted that he has responsibility for the safe running of the Council business.	<b>Yes</b>		Maintain and monitor existing controls.	
Training has been provided to ensure that key persons are competent to undertake their health and safety responsibilities.	<b>Yes</b>		Maintain and monitor existing controls.	
Staff have been informed to whom they should report any concerns about health and safety issues, so that the management can address them.	<b>Yes</b>		Maintain and monitor existing controls.	

<b>CURRENT CONTROLS</b>	<b>YES</b>	<b>NO</b>	<b>ACTION REQUIRED</b>	<b>PRIORITY</b>
<b>Monitoring and measurement</b>			<b>Managing Monitoring and Measurement</b>	
The Health and Safety action plan is prioritised and monitored to ensure actions are taken in suitable time frame		<b>No</b>	Set suitable priorities for the safety action plan and monitor regularly	<b>4</b>
The company has established performance criteria for health and safety		<b>No</b>	Establish monitoring and performance criteria for health and safety. This will help work to a programme of continuous improvement.	<b>4</b>
<b>Communication and consultation</b>			<b>Managing Communication and consultation</b>	
Suitable arrangements are in place for communicating with and consulting staff on Health and Safety matters.		<b>No</b>	Arrangements must be put into place for communicating with and consulting staff on Health and Safety matters.	<b>4</b>
<b>Employee Training</b>			<b>Managing Employee Training</b>	
Induction training for new staff includes health and safety subjects.		<b>No</b>	Provide all new staff with health and safety instruction as part of their induction training.	<b>3</b>
Arrangements have been made for staff to be given basic Health and Safety training.		<b>No</b>	Develop a programme of basic Health and Safety training for staff.	<b>4</b>
Accurate records of the training provided are maintained.	<b>Yes</b>		Maintain and monitor existing controls.	
Training needs are regularly re-assessed as jobs change and refresher training is carried out as and when needed.	<b>Yes</b>		Maintain and monitor existing controls.	
<b>Statutory Notices</b>			<b>Managing Statutory Notices</b>	
The Health and Safety Law poster is displayed in a conspicuous position and all the information boxes have been completed.	<b>Yes</b>		Maintain and monitor existing controls.	
A copy of the employers' liability insurance certificate is displayed on notice board or electronically	<b>Yes</b>		Maintain and monitor existing controls.	
No smoking signs are displayed at entrance to buildings	<b>Yes</b>		Maintain and monitor existing controls.	
<b>Risk Assessment</b>				
Risk assessments are in place for the company's activities		<b>No</b>	Ensure risk assessments are in place for specific activities that are not covered in the general risk assessment	<b>4</b>

<b>CURRENT CONTROLS</b>	<b>YES</b>	<b>NO</b>	<b>ACTION REQUIRED</b>	<b>PRIORITY</b>
Risk assessments are carried out by suitably competent persons		<b>No</b>	Ensure competent persons are employed to carry out risk assessments.	<b>4</b>
A programme of risk assessment review is established		<b>No</b>	Establish a programme of risk assessment review. This should be done at least annually and when any significant changes.	<b>4</b>
Staff are informed of the risks and precautions established in the risk assessments		<b>No</b>	Ensure staff are given access to risk assessments and changes are notified.	<b>4</b>
<b>Accident Reporting/Recording</b>			<b>Managing Accident Reporting/Recording</b>	
There is a near miss or incident reporting procedure		<b>No</b>	Make suitable arrangements to include near miss / incident reporting	<b>3</b>
All serious accidents and/or incidents are investigated to determine the probable cause.		<b>No</b>	Investigate the details of each serious accident/incident to identify the probable cause(s) and/or trends.	<b>3</b>
An Accident Book is provided for the recording of accidents.	<b>Yes</b>		Maintain and monitor existing controls.	
<b>Contractors</b>			<b>Managing Contractors</b>	
Contractors engaged for the company have been assessed for safety prior to engagement		<b>No</b>	Review safety systems and procedures of contractors prior to engagement. Undertake assessment of health and safety standards adopted by the contractors.	<b>3</b>